

RANCHO SANTIAGO COMMUNITY COLLEGE DISTRICT



ADDENDUM NO. 1

Bid #1452 MCHS Roof Replacement Project
at
Santa Ana College

Address: 1530 W 17th St, Santa Ana, CA 92706

Project ID #3737

January 29, 2024

Owner:
Rancho Santiago Community College District
2323 North Broadway, Room 112
Santa Ana, California 92706

**RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED ON BID FORM WHEN
SUBMITTED**

The following changes, additions, deletions or corrections shall become a part of the Contract Documents for the project named on the previous page and all other conditions shall remain the same. The Bidders shall be responsible for transmitting this information to all affected Subcontractors and Suppliers, prior to the closing of Bids. Prospective Bidders shall acknowledge receipt of all Addenda in the space provided on the Bid Proposal Form by the number (list every addenda). Failure to do so shall deem the Bid Proposal as non-responsive and subject the Bidder to disqualification.

Item No. AD 1-1 Responses to Pre-Bid Clarification Questions

The following provides a response to the Bidder's Request for Pre-Bid Information submitted on the Pre-Bid Clarification Form. See attached for a total of (1) RFI Response(s).

Enclosure: One (1) Pre-Bid Clarification Form Response

This is the end of Addendum No. 1

PRE-BID CLARIFICATION FORM

(Email this completed form to FacilitiesBid@rsccd.edu. See Instructions to Bidders.)

| | | | |
|---|--|-----------------|-------------------------------|
| PROJECT NAME: | MCHS Roof Replacement Project at Santa Ana College | | |
| PROJECT NUMBER: | 24-03 | BID NUMBER: | 1452 |
| EMAIL TO: facilitiesbid@rsccd.edu | | | |
| DATE: | 1/17/2024 | | |
| FROM: | AME Builders, Inc. | EMAIL: | rick.delaloza@amebuilders.net |
| SPEC SECTION: | Attachment A, SOW, Single Story Portables,#12 | DRAWING NUMBER: | N/A |
| REQUESTED CLARIFICATION: | | | |
| Please advise if seamless gutters are a requirement. SMACNA guidelines call for an expansion joint for every 50' of gutter and this will be impossible with seamless gutters. | | | |
| RESPONSE TO CLARIFICATION: | | | |
| District: Provide 22 gauge 5" D style box with Kynar finish gutters. Install per SMACNA. | | | |

Attach additional numbered sheets as necessary; however, only one (1) request shall be contained on each submitted form.

END OF DOCUMENT